




Collier County Fire Prevention and Protection Code POLICY AND PROCEDURE MANUAL



ARTICLE NUMBER: HYD 09 - 4

EFFECTIVE DATE: 1/1/2009

SUBJECT: Structures that are within a 1000' of a Water Main

OBJECTIVE: To clarify when new construction of all Commercial projects and new single family subdivisions are required to connect to an existing central water supply.

BACKGROUND: NFPA 18.3.1 allows the A.H.J. to require the minimum distance to fire hydrant system that the structures listed above need to connect to fire hydrants line.

POLICY/PROCEDURE: All commercial projects and new single family subdivisions that are located within a 1000' of a fire hydrant need to be connected to the central water supply system.

CODE REFERENCES: NFPA 18.3.1 2007 Edition. NFPA 24 2002 Edition

ATTACHMENTS: None.

DISTRIBUTION: Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers